

# CERTIFICATE FI/40571/A1

Our Ref. HEL-CERT200200056-02



<b>Product</b>	Conduit for electrical installations, pliable
<b>Type</b>	16HF-A-SC ICTA, 20HF-A-SC ICTA, 25HF-A-SC ICTA
<b>Trademark</b>	Aalto
<b>Certificate Holder</b>	Wirell Oy Nappikuja 2, 82200, Hammaslahti, Finland
<b>Technical information</b>	Classification Code 3442. Non-flame propagating corrugated conduits of grey colored insulating material with size 16 mm, 20mm and 25mm. Temperature range: -25°C / +90°C. Compression force: 750N
<b>Other information</b>	No halogen according to EN 60754-2 and passes smoke density test according EN61034-2.
<b>The product is certified according to the following standard(s)</b>	EN 61386-1:2008 + A1:2019 EN IEC 61386-22:2021 + A11:2021
<b>Validity</b>	This certificate is valid until 2027-02-15 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.
<b>Date of issue</b>	2024-12-20
<b>SGS Fimko Ltd</b>	

**Signature**

Joonas Leinonen

Certification Manager

SGS

**Manufacturer**

Wirell Oy  
Nappikuja 2, 82200, Hammaslahti, Finland

**Manufacturing site**

Wirell Oy  
Nappikuja 2, 82200, Hammaslahti, Finland

**Directive information**

The certified product(s) fulfils requirements of mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

**Additional information**

The products have certificate no. SE-S-2100171R1 issued by Intertek Semko AB in accordance with the Nordic Certification Service system.

This certificate replaces previous certificate FI/40571 dated 2020-02-06 due to updated standard.

**As shown in the Test Report(s) No(s):** 2020984STO-001, 2020979STO-001, 1817984STO-002