

 **CERTIFICATE**  
**FOR EUROPEAN PRODUCT SAFETY**

Reference No. SE-S-2100171R1

## Conduit for electrical installations

**Type designation:** 16HF-A-SC ICTA, 20HF-A-SC ICTA, 25HF-A-SC ICTA

**Certificate holder:**  
Wirell Oy  
Nappikuja 2  
82200 Hammaslahti  
Finland

**The product complies with the standard(s):** EN 61386-1:2008 + A1  
EN IEC 61386-22:2021+A11

**Date of expiry:** 15 February, 2027

Additional information in Appendix

**Certification Body:** Intertek Semko AB, Product Certification

**Signed:**

**Place:** Kista - Stockholm

**Date:** 15 February, 2022

  
Henrik Wikström

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX:

Reference No. SE-S-2100171R1

### Technical Data:

<i>Type designation</i>	16HF-A-SC ICTA, 20HF-A-SC ICTA, 25HF-A-SC ICTA
<i>Trademark</i>	Aalto
<i>Classification coding</i>	3442
<i>Test Report</i>	2020984ST0-001
<i>Product information</i>	Non-flame propagating corrugated conduits of grey colored insulating material with size 16 mm, 20 mm and 25 mm. Temperature range: -25°C / +90°C Compression force: 750N
<i>Other information</i>	Material content of the conduits: No halogen according to EN 60754-2 and passes smoke density test according EN61034-2.

### Manufacturing Sites:

Wirell Oy  
Nappikuja 2  
82200 Hammaslahti  
Finland

This certificate replaces the certificate with Ref. No. SE-S-2100171, dated 02 February 2021 due to updated standard and testing different materials.

**Certification Body:**

Intertek Semko AB, Product Certification

**Place:** Kista - Stockholm

**Signed:**



**Date:** 15 February, 2022

Henrik Wikström

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.